
CROUSE-HINDS

MTL7700 range

DIN-rail mounting safety barriers

- Removable terminals
- Bussed power feed to other modules
- Relay and solid state switch modules
- Dual channel variants 6.3mm per channel
- Proximity detector inputs
- Electronic fusing
- Direct replacement for MTL700 range barriers
- Compatible terminal numbering and safety descriptions



Since its introduction in 1984 the MTL700 range has established itself as the worldwide standard for safety barriers. Known for its quality and reliability, the MTL700 range is widely used in applications all over the world.

The MTL7700 range follows closely in the footsteps of the MTL700, but as a DIN rail mounting barrier, providing quick and easy installation without the need for special hardware.

Removable terminals are used for ease of installation, maintenance and for providing a loop disconnect by simply unplugging the terminals from the side of the module. Wire entry is also angled to assist wiring within limited space enclosures.

MTL7700 barriers clamp simply and securely onto standard T-section DIN rail, simultaneously making a reliable IS earth connection.

For applications where field power is required for switch inputs or 2-wire transmitters, the MTL7700 range provides a bussed power feed facility. When used in conjunction with the MTL7798 power feed module the user has a fully protected, electronically fused supply to many barriers with no additional wiring required.

MTL7700 active modules are protected with an electronic fuse for the majority of applications. The MTL7798 active fused, power feed module can protect up to 40 other modules using the bussed power facility and provides a clear indication of a trip condition via a red LED.

The MTL774X range of barriers offer a NAMUR compatible input and a choice of relay or solid state output. The solid state outputs are floating so switching to ground or from a power rail into an input is also possible. The solid state interface also provides a high frequency transfer for use in flow or rotation applications.

Dual channel relay or solid state modules offer the highest packing density with only 6.3mm per channel and when used in conjunction with the power bus, offer users the minimum of wiring with the maximum packing density and the lowest cost per channel.



Eaton Electric Limited,

Great Marlings, Butterfield, Luton Beds, LU2 8DL, UK. Tel: + 44 (0)1582 723633 Fax: + 44 (0)1582 422283 E-mail: mtlenquiry@eaton.com www.mtl-inst.com

© 2017 Eaton All Rights Reserved Publication No. EPS7700 Rev 12 200917 September 2017

EUROPE (EMEA):

+44 (0)1582 723633 mtlenguiry@eaton.com

THE AMERICAS:

+1 800 835 7075 mtl-us-info@eaton.com

sales.mtlsing@eaton.com

ASIA-PACIFIC: +65 6 645 9888

The given data is only intended as a product description and should not be regarded as a legal warranty of properties or guarantee. In the interest of further technical developments, we reserve the right to make design changes.

SPECIFICATIONS

For notes 1 to 7 see 'Terminology' (later in this section)

'Key' barriers shown in blue

Model No.	1 Safety description			Polarities ² available		ies ² le	Application	Basic circuit	Max. end- ³ to-end resistance	Vwkg at ⁴ 10µA or (1µA)	5 Vmax	Fuse ⁶ rating
MTL	V	Ω	mA	+	-	ac		Hazardous Safe	Ω	V	V	mA
7706+	28	300	93	V			Transmitters				35	50
7707+	28	300	93	1			Switches	See 'HOW THEY WORK'		.000	35	50
	28	diode						and 'ACTIVE / ELECTRONICALLY	See ad specifi		35	50
7707P+	28	164	171	1			Transmitters, switches,	PROTECTED BARRIERS'	Specifi	Cation	35	50
	28	diode	_				controller outputs IIB				35	50
7710+/-	10	50	200	1	1				75	6.0	7.0	50
7715+	15	100	150	1			6V dc & 4V ac systems	o • • • • •	119	12.0	13.1	100
7715P+	15	50	291	1			12V systems	3 — — 1	64	12.3	13.4	100
7722+/-	22	150	147	1	✓		12V dc systems	* *	174	19.6	20.2	50
7728+	28	300	93	✓			18V dc systems Controller outputs, solenoids		333	25.9	26.5	50
7728-	28	300	93		1		Transmitters	Q 4 = 0 2	333	25.9	26.5	50
7728ac	28	300	93			1	Controller outputs, solenoid valves		333	25.0	25.9	50
7728P+	28	234	119	1			Controller outputs, solenoid valves IIB		252	24.9	25.9	100
7729P+	28	164	170	V					184	24.9	25.9	100
774X	10	_	19				Prox sw input, solid state output and line fault detect	See 'ACTIVE / ELECTRONICALLY PROTECTED BARRIERS'	_	_	30/35	50
								30				
7755ac	3	10	300			/	2- or 3-Wire RTDs		19.0	(1)	3.4	250
	3	10	300			/	(floating bridge)		19.0	(1)	3.4	250
		10	000			ľ		40 02	10.0	(1)	0.4	200
								70				
7756ac	3	10	300			/	3-Wire RTDs	_ * * * _	19.0	(0.7)	2.7	250
	3	10	300	İ		1	(grounded bridge)	3°	19.0	(0.7)	2.7	250
	3	10	300	İ		1			19.0	(0.7)	2.7	250
								40 02				
7758+/-	7.5	10	750	V	V		Gas detectors		17	6.0	7.3	200
7704	7.5	10	750					30	17	6.0	7.3	200
7761ac	9	90	100			1		* * *	107	6.0	7.0	100
77C1Daa	9	90	100			١,	Chroin annua baidean	 	107	6.0	7.0 7.5	100
7761Pac	9	350 350	26 26			V	Strain-gauge bridges		378 378	6.8 6.8	7.5	50 50
7764+/-/ac	12	1k	12	/	/	/	Strain-gauge bridges	4 0 0 2	1050	10.0	10.9	50
//04+/-/ac	12	1k	12	"	"	"	Strain-gauge bridges		1050	10.0	10.9	50
7766ac	12	150	80			1			174	10.0	10.6	50
	12	150	80			•			174	10.0	10.6	50
7766Pac	12	75	157			/	Strain-gauge bridges		92	9.6	10.5	100
	12	75	157				Strain-gauge bridges		92	9.6	10.5	100
7767+	15	100	150	1			12V dc systems		119	12.0	13.1	100
	15	100	150	İ			12V dc systems		119	12.0	13.1	100
7779+	28	300	93	1			Controller outputs	requires channels	333	25.9	26.5	50
	28	300	93				Controller outputs	separate in IIC	333	25.9	26.5	50
7796+	26	300	87	✓			Vibration probes		333	23.9	24.5	50
	20	390	51						428	18.3	18.9	50
7796-	26	300	87		1		Vibration probes		333	23.9	24.5	50
7700	20	390	51		-		Assistant C		428	18.3	18.9	50
7760ac	10	50	200			V	Active dc & ac sensors Thermocouples		75	6.0	6.7	50
7705	10	50	200				memocouples	3° L 3° 1	75	6.0	6.7	50
7765ac	15	100	150			√		Ĭ⊳± ₽₹	124	12.0	12.5	50
7770-	15	100	150						124	12.0	12.5	50
7778ac	28 28	600 600	47 {			V		40 0 2	651 651	24.0 24.0	25.4 25.4	50 50
7789+	28	300	93 ^a	1				30 ++ + ++0 1	651	26.6	27.2	50
							Switch inputs /	70	651	26.6	27.2	50
			[Signal returns	_ 				
	28	diode	_					40 0 2	0.9V+26Ω	26.6	27.2	50
	28	diode	_					80 6	0.9V+26Ω	26.6	27.2	50
7787+/-	28	300	93	√	√		Transmitters	3 0 1	333	26.6	27.2	50
	28	diode	_				Controller outputs, switches	↑ ★	0.9V+21Ω	26.6	27.2	50
7787P+	28	234	119	1				+ +	253	26.4	27.2	80
	28	diode	_	L		L		40 0 2	0.9V+21Ω	26.4	27.2	80
'		200	93					30-T	333	25.9	26.5	50
7788+	28	300	93	✓					000	20.0	20.0	
7788+	28 10	50	200	/			Transmitters		75	6.0	7.0	50
7788+ 7788R+							Transmitters					

^a Terminals 3 & 7 connected together

^{*} Diagrams show positive versions. All diodes reversed on negative versions. Additional diodes fitted on ac versions.



Eaton Electric Limited, Great Marlings, Butterfield, Luton Beds, LU2 8DL, UK. Tel: + 44 (0)1582 723633 Fax: + 44 (0)1582 422283 EPS7700 Rev 12 200917 E-mail: mtlenquiry@eaton.com www.mtl-inst.com

© 2017 Eaton All Rights Reserved Publication No. EUROPE (EMEA): +44 (0)1582 723633 mtlenquiry@eaton.com THE AMERICAS:

+1 800 835 7075 mtl-us-info@eaton.com ASIA-PACIFIC: +65 6 645 9888 sales.mtlsing@eaton.com

HOW THEY WORK

All MTL7700 range barriers are based on the same simple principle. Each channel contains two stages of pulse-tested Zener or forwardconnected diodes and an 'infallible' terminating resistor. In the event of an electrical fault in the safe area, the diodes limit the voltage that can reach the hazardous area and the resistor limits the current. A fuse protects the diodes, and the two stages of voltage limitation ensure continued safety if either stage should fail. No active outputcurrent limiting circuits are employed. All models are certified 'ia' for all zones and 'IIC' for all explosive atmospheres (except MTL7707P+ and MTL7729P+, 'ia' 'IIB').

TERMINOLOGY

1. Safety description

The safety description of a barrier, eg '10V 50Ω 200mA', refers to the maximum voltage of the terminating Zener or forward diode while the fuse is blowing, the minimum value of the terminating resistor, and the corresponding maximum short-circuit current. It is an indication of the fault energy that can be developed in the hazardous area, and not of the working voltage or end-to-end resistance.

2. Polarity

Barriers may be polarised + or -, or non-polarised ('ac'). Polarised barriers accept and/or deliver safe-area voltages of the specified polarity only. Non-polarised barriers support voltages of either polarity applied at either end.

3. End-to-end resistance

The resistance between the two ends of a barrier channel at 20°C, i.e. of the resistors and the fuse. If diodes or transistors are present, their voltage drop (transistors ON) is quoted in addition.

4. Working voltage (Vwkg)

The greatest steady voltage, of appropriate polarity, that can be applied between the safe-area terminal of a 'basic' barrier channel and earth at 20°C for the specified leakage current, with the hazardous-area terminal open circuit.

5. Maximum voltage (Vmax)

The greatest steady voltage, of appropriate polarity, that can be applied continuously between the safe-area terminal of any barrier channel and earth at 20°C without blowing the fuse. For 'basic' barriers, it is specified with the hazardous-area terminal open circuit; if current is drawn in the hazardous area, the maximum voltage for these barriers is reduced. The 'ac' channels of 'basic' barriers and most channels of overvolt-protected barriers withstand voltages of the opposite polarity also - see circuit diagrams.

6. Fuse rating

The greatest current that can be passed continuously (for 1000 hours at 35°C) through the fuse.

7. Star connection

In star-connected barriers, the two channels are interlocked such that the voltage between them cannot exceed the working voltage, Vwkg: this allows for higher cable capacitance or inductance.

8. Maximum safe-area voltage (U_m)

The maximum permissible safe-area voltage (U_m) for MTL7700 range barriers is 250V ac/dc.

GENERAL SPECIFICATION

Ambient temperature and humidity limits

-20 to +60°C continuous working -40 to +80°C storage 5-95% RH

Leakage current

For 'basic' barriers with a working voltage of 5V or more, the leakage current decreases by at least one decade per volt reduction in applied voltage below the working voltage, over two decades. For the MTL7755ac/7756ac it decreases by at least one decade for a 0.4V reduction in applied voltage.

Terminations

Removable terminals accommodate conductors up to 2.5mm² (13AWG). Hazardous-area terminals are identified by blue labels. Removal force >15N

Colour coding of barrier label

Grey: non-polarised

Red: positive polarity (MTL7706 negative to transmitter)

Black: negative polarity

White: dummy barrier, MTL7799


Weight

140g approx

Mounting and earthing

By 35mm Top Hat DIN rail

DIMENSIONS (mm)



Product top label Colour-coded top label

MTL7700 RANGE KEY BARRIERS SUMMARISED

TYPE	APPLICATION	KEY BARRIER
Analogue input (low-level)	Resistance temperature detectors Thermocouples, ac sensors	7756ac 7760ac
Analogue input (high-level)	Transmitters, 2-wire, 4/20mA	7706+ 7787+
Analogue output	Controller outputs, one line earthed Controller outputs, neither line earthed	7728+ 7787+
Digital (on/off) input	Switches	7787+ 7741/3
Digital (on/off) output	Solenoids, alarms, LEDs	7728



Great Marlings, Butterfield, Luton Beds, LU2 8DL, UK. Tel: + 44 (0)1582 723633 Fax: + 44 (0)1582 422283 E-mail: mtlenquiry@eaton.com www.mtl-inst.com

© 2017 Eaton All Rights Reserved Publication No. EPS7700 Rev 12 200917 EUROPE (EMEA):

+44 (0)1582 723633 mtlenguiry@eaton.com

THE AMERICAS:

+1 800 835 7075 mtl-us-info@eaton.com

ASIA-PACIFIC:

+65 6 645 9888 sales.mtlsing@eaton.com

ACTIVE / ELECTRONICALLY PROTECTED BARRIERS

ACTIVE / ELECTRONICALLY PROTECTED BARRIERS

The following barriers have built-in overvolt protection, allowing their use with unregulated power supplies. In many applications, eg, sensor inputs or controller outputs, there is insufficient power available to blow the barrier fuse and this additional protection is not necessary. However, where the barrier is connected to a power supply, eg, for energising transmitters, switches, solenoids or local alarms, overvolt protection allows the barriers to be used with unregulated supplies and also gives protection against faulty wiring during commissioning.

MTL7706+ for 'smart' 2-wire 4/20mA transmitters


The MTL7706+ is a 1-channel shunt-diode safety barrier, with built-in electronic overvolt protection, for energising a 2-wire, 4/20mA transmitter in a hazardous area. It is powered from a positive supply of 20–35V dc and delivers a 4/20mA signal into an earthed load in the safe area. It is proof against short circuits in the field and in the safe area and is extremely accurate. The MTL7706+ will pass incoming communication signals up to 10kHz from a 'smart' transmitter, while in the outgoing direction it will pass signals of any frequency likely to be encountered.

Since the MTL7706+ has no return channel for energising the load, the entire output of the single '28V' channel is available to power the transmitter, providing high output capability. This channel is negatively polarised, and the safe-area signal is in fact the very current that returns through it from the hazardous area, the novel circuit being energised by a built-in floating dc supply derived from the external dc source of power

To prevent any leakage through the zener diodes and maximise the output voltage available at 20mA, the floating supply is given a rising voltage/current characteristic. A separate circuit limits the current to protect the fuse in the event of a short circuit in the hazardous area.

With a 20V supply, the barrier will deliver 16.2V minimum at 20mA for the transmitter and lines and consumes typically 45mA at 24V operation.

BASIC CIRCUIT



ADDITIONAL SPECIFICATION

Safety description

 $28V~300\Omega~93mA$

Supply voltage

20 to 35V dc w.r.t earth

Output current

4 to 20 mA

Voltage available to transmitter and lines

16.2V @ 20mA with 250Ω load (negative w.r.t. earth) 11.0V @ 20mA with 500Ω load (negative w.r.t. earth)

Accuracy

±2uA under all conditions

Safe-area load resistance

0 to 500Ω

Supply current

45mA typical at 20mA and 24V supply 60mA maximum at 20mA and 20V supply


MTL7707+ for switch inputs and switched outputs

The MTL7707+ is a 2-channel shunt-diode safety barrier similar to the MTL7787+ but with built-in electronic overvolt protection. It is intended primarily for safeguarding a hazardous-area switch controlling a relay, opto-coupler or other safe-area load from an unregulated dc supply in the safe area.

The outgoing channel accepts supply voltages up to +35V and is protected against reverse voltages: the return channel is unaffected by voltages up to +250V.

In normal operation the protection circuit introduces only a small voltage drop and shunts less than 1mA to earth, so its overall effect is minimal. If the supply voltage exceeds about 27V, however, causing the Zener diodes to conduct – or if the safe-area load has a very low resistance – the supply current is limited automatically to 50mA, protecting the fuse and power supply and enabling the loop to continue working.

BASIC CIRCUIT



ADDITIONAL SPECIFICATION

Safety description

28V 300 Ω 93mA, terminals 1 to 3 28V Diode, terminals 2 -4

Supply voltage

10 to 35V dc with respect to earth

Output current

Up to 35mA available

Maximum voltage drop

(at 20°C, current not limited)

lout x 345 Ω + 0.3V, terminals 1 to 3 lout x 25 Ω + 0.9V, terminals 4 to 2

Supply current

lout + 1.6mA, supply <26V Limited to 50mA, supply >28V or low load resistance

MTL7707P+ for switch inputs and switched outputs, 2W Transmitters (IIB gases)

The MTL7707P+ is a two-channel shunt-diode safety barrier similar to the MTL7787P+, but is designed for use with group IIB gases and features built-in electronic overvolt protection allowing use with unregulated power supplies up to 35V dc. It is intended primarily as a low cost solution for driving IIB certified 2-wire 4/20mA transmitters, but can also be used with controller outputs with current monitoring, solenoid valves and switches. To protect the fuse and enable the loop to continue working, the supply current is limited automatically at 50mA should the output be short-circuited or excess voltage applied.

The given data is only intended as a product description and should not be regarded as a legal



Eaton Electric Limited,


Great Marlings, Butterfield, Luton Beds, LU2 8DL, UK. Tal. + 44 (0)1582 723633 Fax: + 44 (0)1582 422283 E-mail: mtlenquiry@eaton.com www.mtl-inst.com © 2017 Eaton All Rights Reserved Publication No. EPS7700 Rev 12 200917 EUROPE (EMEA):

+44 (0)1582 723633 mtlenquiry@eaton.com

THE AMERICAS:

+1 800 835 7075 mtl-us-info@eaton.com

BASIC CIRCUIT



ADDITIONAL SPECIFICATION

Safety description

28V 164Ω 171mA, terminals 1 to 3 28V Diode, terminals 4 to 2

Supply voltage

10 to 35V dc with respect to earth

Output current

Up to 35mA available

Maximum voltage drop

(at 20°C, current not limited)

lout x $218\Omega + 0.3V$, terminals 1 to 3 lout x $20.1\Omega + 0.9V$, terminals 4 to 2

Supply current


lout + 1.6mA, supply <26V

Limited to 50mA, supply >28V or low load resistance

MTL7741 proximity sensor or switch input and relay output

The MTL7741 is a single channel switch/prox input barrier with changeover relay contacts acting as the safe area interface. Relay contacts provide a universal interface capable of switching a wide range of signals including ac, low level and high level voltages. Phase reversal is achieved by connecting the normally open or normally closed contacts as required. The power bus terminal may be used to connect the module to a power source.

BASIC CIRCUIT



ADDITIONAL SPECIFICATION

Safety description

10V 19mA

Supply voltage

22.9 to 30V dc with respect to earth

Input characteristics

Relay energised if input >2.1mA($<2k\Omega$) Relay de-energised if input <1.2mA(>10kΩ)

Relay Contacts

33V ac 0.5A. Resistive 30V dc, 1A. Resistive

Supply current

26mA maximum @ 24V


Response time

<10 ms

MTL7742 proximity sensor or switch input with solid state output

The MTL7742 is a single channel switch/prox input barrier with an open collector solid state interface to the safe area equipment. The solid state switch is especially useful for high frequency switching apparatus including pulse and rotational sensors. The power bus terminal can be used to connect power to the module and the input power supply range makes the module suitable for use with unregulated supplies.

BASIC CIRCUIT



ADDITIONAL SPECIFICATION

Safety description

10V 19mA

Supply voltage

20 to 35V dc with respect to earth

Input characteristics

Output energised if input >2.1mA(<2k Ω) Output de-energised if input <1.2mA(>10k Ω)

Output characteristics

Operating frequency dc to 2.5kHz Max off-state voltage 35V Max off-state leakage 10μΑ

Max on-state voltage drop <1.41V @ 50mA, <1.22V @ 2mA

typically <1V

Max on-state current 50mA


Supply current

20mA maximum @ 24V

MTL7743 2 channel proximity sensor or switch input and relay outputs

The MTL7743 is a dual channel switch/prox sensor input barrier with a relay interface. This module is ideal for applications where high channel packing densities are required for digital inputs. Power is connected using the power bus terminal.

BASIC CIRCUIT



ADDITIONAL SPECIFICATION

Safety description

10V 19mA

Supply voltage

22.9 to 30V dc with respect to earth

Input characteristics

Relay energised if input >2.1mA(<2kΩ) Relay de-energised if input $<1.2mA(>10k\Omega)$

Relay Contacts

AC 33V, 0.5A. resistive; DC 30V, 1A. resistive

Supply current

45mA maximum @ 24V

Response time

<10ms



Great Marlings, Butterfield, Luton Beds, LU2 8DL, UK. Tel: + 44 (0)1582 723633 Fax: + 44 (0)1582 422283 E-mail: mtlenquiry@eaton.com www.mtl-inst.com

© 2017 Eaton All Rights Reserved Publication No. EPS7700 Rev 12 200917 EUROPE (EMEA):

+44 (0)1582 723633 mtlenguiry@eaton.com

THE AMERICAS:

+1 800 835 7075 mtl-us-info@eaton.com


ASIA-PACIFIC:

+65 6 645 9888 sales.mtlsing@eaton.com

MTL7744 2 channel proximity sensor or switch inputs with solid state outputs

A dual channel version of the MTL7742. This module provides two solid state interfaces for prox/switch inputs. Power is connected via the power bus.

BASIC CIRCUIT



ADDITIONAL SPECIFICATION

Safety description

10V 19mA 10V 19mA

Supply voltage

20 to 35V dc with respect to earth

Input characteristics

Output energised if input >2.1mA(<2k Ω) Output de-energised if input <1.2mA(>10k)

Output characteristics

Operating frequency dc to 2.5kHz
Max off-state voltage 35V
Max off-state leakage 10µA

Max on-state voltage drop 1.41V @ 50mA, 1.22V @ 2mA

 $\begin{tabular}{ll} typically < 1V \\ Max on-state current \\ \end{tabular}$


Supply current

29mA maximum @ 24V

MTL7745 proximity sensor or switch input with relay output and line fault detect

The MTL7745 is a single channel switch/prox input barrier providing line fault detection. Proximity detectors or switches fitted with end-of-line resistors may be connected. Short circuit or open ciruit conditions in the field wiring will generate an alarm condition. The LFD relay contacts close when a fault is detected allowing the contacts to be connected in parallel to provide a common alarm. The power bus terminal can be used to connect power to this module.

BASIC CIRCUIT



ADDITIONAL SPECIFICATION

Safety description

10V 19mA

Supply voltage

22.9 to 30V dc with respect to earth

Input characteristics

Output energised if input >2.1mA(<2k Ω) Output de-energised if input <1.2mA(>10k Ω)

LFD relay + Red LED

Energised if input $<50\mu A$ or $<100\Omega$

Powering Business Worldwide

Eaton Electric Limited,

Great Marlings, Butterfield, Luton Beds, LU2 8DL, UK. Tel: + 44 (0)1582 723633 Fax: + 44 (0)1582 422283 E-mail: mtlenquiry@eaton.com www.mtl-inst.com © 2017 Eaton All Rights Reserved Publication No. EPS7700 Rev 12 200917

Relay contacts 33V ac 0.5A. Resistive

30V dc, 1A. Resistive **Supply current**

Supply current

38mA maximum @ 24V


Response time

<10ms

MTL7798 Power feed and protection module

The MTL7798 power feed module incorporates both voltage and current sense mechanisms to protect barrier circuits by activating a solid state trip mechanism when fault or overload conditions occur in the power source circuit. Resetting the module after tripping is achieved by interupting the supply to the unit. A red LED indicates a circuit trip condition and a green LED the availability of power at the outputs. Bussed power for other modules is sourced from the top of the unit using the Bus Power Link BPL7700 or via terminals 1 and 2.

BASIC CIRCUIT



ADDITIONAL SPECIFICATION

Input voltage range (terminals 5&6)

20 to 26.8V

Maximum input voltage capability

45V

Power source requirements

>1.8A

Trip mechanism

Minimum trip 26.8V @ 20°C (+18mV/°C)

Output current range

0 to 800mA

Maximum voltage drop

20mV @ 0mA, 1.0V @ 800mA load

EUROPE (EMEA):

+44 (0)1582 723633 mtlenquiry@eaton.com

THE AMERICAS:

+1 800 835 7075 mtl-us-info@eaton.com
ASIA-PACIFIC:

MTL7700 RANGE BARRIER APPLICATIONS


ANALOGUE INPUTS (HIGH LEVEL)


2-wire transmitters, 4/20mA, conventional and smart


The recommended barrier for use with 'conventional' and 'smart' 4/20mA transmitters (fed by a 26V regulated supply) is the MTL7787+. This provides up to 12.9V (14.6V for MTL7787P+) at Vwkg and 20mA for a transmitter and its lines as well as 5V for the typical 250Ω load. This application and this barrier is suitable for use with the optional power bus facility.


The MTL7706+ is recommended for applications where an unregulated supply of up to 35V is used. It provides 16.0V for conventional and Smart transmitters at 20mA, as well as 5V for a typical 250 Ω load. With the MTL7706+ terminal 3 is negative with respect to earth, so the connections to terminals 3 and 4 should be reversed.


MTL7700 range barriers protect devices located in all normally occurring explosive atmospheres, including air/flammable gas mixtures, dusts and fibres. Applications covered include the protection of installations incorporating uncertified devices ('simple apparatus') such as thermocouples, switches and resistive sensors, or separately certified 'energy storing' (or 'voltage producing') apparatus including ac sensors, transmitters and current-to-pneumatic (I/P) converters. Recommended choices for specific applications are discussed briefly in the following pages.














Vibration probes

The 3-wire transmitters used with vibration monitoring equipment are invariably supplied by a -24V dc power supply - hence the recommended barrier choice is the negatively-polarised MTL7796-.

ANALOGUE INPUTS (LOW-LEVEL)

Thermocouples and mV sources

The recommended barrier for thermocouples and mV sources is the MTL7760ac. This 2-channel non-polarised barrier retains the 'earthfree' nature of the signal and, providing the receiver's input 'floats', rejects common-mode ac and dc interference up to at least 7V and is unaffected by earth faults on the primary element.

AC sensors, photocells, microphones and turbine flowmeters

The MTL7760ac is the recommended choice for these devices. While many of these are designated 'simple apparatus' and thus do not need certification, note that some ac sensors may be subject to a significant level of inductance and will therefore need to be designed and certified for hazardous-area locations.

Slidewire displacement transducers

The simplest choice is the MTL7760ac. This barrier supplies power and brings back a unipolar signal.



EPS7700 Rev 12 200917

Beds, LU2 8DL, UK.
Tel: + 44 (0)1582 723633 Fax: + 44 (0)1582 422283
E-mail: mtlenquiry@eaton.com
www.mtl-inst.com

ASIA-PACIFIC: +65 6 645 9888 sales.mtlsing@eaton.com

+1 800 835 7075 mtl-us-info@eaton.com


RTDs

For 3-wire RTDs, a single MTL7755ac barrier is the most economical choice. This is suitable for use with a floating bridge – the two leads from the bridge arms are protected by the barrier with the third (supply) lead being earthed through the barrier. The barrier has a low end-to-end resistance of only $19\Omega/\text{channel}$ to minimise span changes and its channels track within 0.15Ω (between –20°C and +60°C) to minimise zero shift with temperature.

If the bridge circuit is already earthed, the third barrier channel provided by an MTL7756ac is needed. For extreme accuracy, 3 channels and an earth-free bridge can be used, a configuration that cancels out the small errors due to barrier leakage.

Channels 1 and 2 (those between terminals 1 & 2 and 3 & 4 respectively) track to within 0.15 $\!\Omega$ (between –20 $^{\circ}$ C and 60 $^{\circ}$ C).

4-wire constant-current circuits do not need matched barrier resistances and can be protected by two MTL7761ac barriers. If the increase in loop resistance is too great, use two MTL7755ac barriers instead



STRAIN-GAUGE BRIDGES


Single strain-gauge bridges

This shows an arrangement using two or three barriers, which is safe in IIC gases.

With the MTL7761ac, the circuit is powered from a 12V (\pm 6V), 214 Ω (107 Ω + 107 Ω) source. If the resistive bridge elements are 230 Ω , then the voltage applied to the bridge will be 6.2V, and if the bridge resistances are 350 Ω , then the bridge's applied voltage will be 7.4V.

An MTL7764ac can be used to sense the bridge supply voltage.

An MTL7761ac is used here for the mV output.





Great Marlings, Butterfield, Luton Beds, LU2 8DL, UK. Tel: + 44 (0)1582 723633 Fax: + 44 (0)1582 422283 E-mail: mtlenquiry@eaton.com www.mtl-inst.com © 2017 Eaton All Rights Reserved Publication No. EPS7700 Rev 12 200917

EUROPE (EMEA):

+44 (0)1582 723633 mtlenquiry@eaton.com THE AMERICAS:

+1 800 835 7075 mtl-us-info@eaton.com

ASIA-PACIFIC:

STRAIN-GAUGE BRIDGES (cont)

Double strain-gauge bridges


Quite frequently there is a demand to monitor two load cells, and a possible circuit, safe in IIC, is shown.

Here, the lower voltage drop of the MTL7766Pac is an advantage.

The MTL7766Pac supplies power to the bridge(s) while two MTL7761Pac barriers interface with the sense and pick-off circuits.

Using 350 $\!\Omega$ bridge systems, the following voltages are available from an MTL7766Pac with a $\pm 10 V$ supply:

1 bridge: 13.11V2 bridges: 9.75V




ANALOGUE OUTPUTS

Controller outputs (I/P converters)

The single-channel MTL7728+ with a voltage drop of 6.66V at 20mA is the recommended choice for most controller outputs. Higher-power versions are available: the MTL7728P+ (5.1V drop) is suitable for IIC applications; the MTL7729P+ (3.68V drop) for IIB applications.

For controllers with an output circuit separated from the 0V rail by the control transistor, the 2-channel MTL7787+ is the preferred choice as the return channel can handle up to 26.6V allowing the control signal to be turned off completely. The voltage drop is 8.1V at 20mA. A higher-power version of the latter, the MTL7787P+, is also available. The return channel of these barriers handle up to 26.4V and the maximum voltage drop is only 6.38V.

The MTL7787+ and MTL7787P+ are also suitable for controllers containing a resistor which enables the return current to be monitored for high-integrity operation.





DIGITAL (ON/OFF) INPUTS

Switches

The normal choice is the MTL7787+/7787P+ with a regulated supply. The MTL774X modules are recommended for applications where an unregulated supply of up to 30V for relay output modules, or 35V for solid state output modules, is used.

The MTL7789+ offers a dual channel passive barrier for switch inputs where the input current for each channel is <10mA.

Switches / Proximity detectors


Eaton's MTL range of new switch/prox input barriers provide the user with a choice of relay and solid state outputs in single and dual channel versions.

The MTL7741 is single channel with a changeover relay output.

The MTL7742 has a single channel solid state switch that can be configured to switch from a power rail or down to ground. This is also ideal for high switching frequency applications.

The MTL7743 and MTL7744 are dual channel versions affording very high packing densities. Power must be provided to these modules using the power bus facility.

The MTL7745 is a single channel proximity input (or switch input if 'end of lines' resistors are fitted) with relay contacts providing switch and line fault status. The LFD relay contacts close when a fault is detected.






DIGITAL (ON/OFF) OUTPUTS

Alarms, LEDs, solenoids valves, etc

For these applications, the MTL7728+ is recommended. Higher-powered versions are available: the MTL7728P+ is suitable for IIC applications; the MTL7729P+ for IIB applications.

If the control switch is to earth, then the 2-channel MTL7787+ barrier should be used, or, alternatively, the MTL7787P+ higher-power version. If the supply is poorly regulated use the MTL7707+.

The MTL7707+ is recommended for applications where an unregulated supply of up to 35V is used.



POSITIVE DC SYSTEMS


Low-level to 12V dc systems

The two channels of the MTL7764+ and MTL7767+ can be combined safely in IIC.

The MTL7764+ can be used for low-level logic return signals whilst the MTL7767+ is used for 6V dc and 12V dc systems.

18V dc systems


The single-channel MTL7722+ is recommended for 18V dc systems.



AC AND DC SYSTEMS

High-level ac and dc systems

The versatile star-connected MTL7765ac and MTL7778ac allow Vwkg to be developed from each channel to ground but only allow Vwkg to be developed between channels. This provides some common-mode voltage capability and can allow higher cable parameters to be used.



NEGATIVE AND FLOATING POWER SUPPLIES

Digital (on/off) outputs


The MTL7728– is used with a negative power supply and positive earth. Typically used for digital inputs or outputs, as shown.

The MTL7728-- can also be used with floating power supplies, for transmitters.

| LED, alarm | 3 | MTL7728 - 1 | 2 | + 1 | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | + 26V | +

SPARE CABLE CORES AND SCREENS

The MTL7799 dummy barrier is used primarily for securing and earthing unused cables and screen connections. Hazardous area terminals 3 and 4 are internally connected to the DIN-rail mounting/earth connection. It also provides a power bus connection for direct connection of power for modules such as the MTL7743 and MTL7744 where no power supply screw terminal is provided.





Eaton Electric Limited,

Great Marlings, Butterfield, Luton Beds, LU2 8DL, UK. Tel: + 44 (0)1582 723633 Fax: + 44 (0)1582 422283 E-mail: mtlenquiry@eaton.com www.mtl-inst.com © 2017 Eaton All Rights Reserved Publication No. EPS7700 Rev 12 200917

EUROPE (EMEA):

+44 (0)1582 723633 mtlenquiry@eaton.com

THE AMERICAS:

+1 800 835 7075 mtl-us-info@eaton.com ASIA-PACIFIC:

POWER BUS APPLICATIONS

The PB7700 power bus is invaluable for saving installation time and wiring when connecting a 24V dc power source to a number of barriers.

Typical applications include hazardous-area switches, 4/20mA transmitters and proximity detectors. The diagram illustrates the configuration for 4 barriers but up to 40 barriers can be served by this method.

The MTL7798 power feed module would normally be used with standard barriers such as MTL7787+ and MTL7787P+ because the current/voltage trip protection mechanism of the MTL7798 protects the fuses in the barriers.

The MTL7799 dummy barrier can be used instead of the MTL7798 for direct 'feed-through' connection of a 24V dc supply onto the power bus. Looping the power feed to each end of the bussed power allows the removal of individual barriers without loss of power to others in the chain.

Other units that can use the power bus facility:

MTL7706

MTL7707+

MTL7707P+

MTL7741

MTL7742

MTL7743

MTL7744

MTL7745


MTL7787+

MTL7787P+

MTL7788+

MTL7788R+

MTL7789+








+1 800 835 7075 mtl-us-info@eaton.com

MTL7700 RANGE ACCESSORIES




MOUNTING/EARTHING ACCESSORIES

MTL7700 range barriers mount easily and quickly onto standard DIN rail which also acts as the intrinsically safe earth.


THR2 standard DIN rail THR7000 plated rail

Specially nickel-plated T-section (35mm \times 7.5mm) DIN rail for use in potentially corrosive atmospheres. Supplied in 1meter lengths.




ISP7000 insulating spacers

Attached to the base of a DIN rail at either end or at intervals (depending upon DIN rail length) to isolate the IS earth from a structural earth.



ERB57S Earth-rail bracket, straight

Nickel-plated; supplied with two push fasteners, one 14mm earth-rail clamp and one 10mm earth clamp for cables ≤16mm² (See ERB570).




ETM7 earth terminal

For terminating cable screens and 0V earth returns and securing spare cores to the earth rail. A maximum of two ETM7s per barrier can be accommodated.




IMB57 Insulating mounting block

One required at each end of a tagging strip/earth rail. Suitable for low-profile (7.5mm) and high-profile (15mm) symmetrical DIN rail.




ERB570 Earth-rail bracket, offset

Nickel-plated; supplied with two push fasteners, one 14mm earth-rail clamp and one 10mm earth clamp for cables ≤16mm².



ETL7000 earth terminal

Provides connection for routing the IS earth from the DIN rail to an appropriate plant earth. Maximum cable cross-section is 10mm². Two recommended per discrete length of DIN rail. See instruction manual INM7700 for more details.



BPL7700 Power Bus link

When a number of barriers use a common power supply, the optional power link (BPL7700) can be used. Typical applications include hazardous area switches, solenoids and 4–20mA transmitters. The barriers it can be used with are the MTL7706, MTL7707+, MTL7787P+, MTL7789P+ and MTL774X. See next page for further details.



Eaton Electric Limited,

www.mtl-inst.com

Great Marlings, Butterfield, Luton Beds, LU2 8DL, UK. Tel: + 44 (0)1582 723633 Fax: + 44 (0)1582 422283 E-mail: mtlenquiry@eaton.com © 2017 Eaton All Rights Reserved Publication No. EPS7700 Rev 12 200917 EUROPE (EMEA):

The given data is only intended as a product description and should not be regarded as a legal

+44 (0)1582 723633 mtlenquiry@eaton.com

THE AMERICAS:


+1 800 835 7075 mtl-us-info@eaton.com
ASIA-PACIFIC:
+65 6 645 9888 sales.mtlsing@eaton.com

TAGGING ACCESSORIES

Two methods of tagging are available which can be used separately or together:

1) Individual barrier identification TH7700 barrier identifiers

TH7700 barrier identifiers are supplied clipped on to the tops of individual barriers to provide transparent holders for identification labels



2) Tagging strip method TAG57 Tagging strip, 1m length

Cut to size. Supplied with reversible tagging strip label suitable for either MTL5000 or MTL7000 range module spacing.

TGL7700 Tagging strip labels, set of 10 x 0.5m

For use with TAG57 tagging strip. Tags are reversible - one side for MTL7700, the other for MTL700.

MTL700 BUSBAR ACCESSORY

ADB700 Adaptor bracket, MTL7700

Tin-plated; supplied with two M4 screws and washers. For mounting an MTL7700 range barrier to an MTL700 busbar (EBB7).

Note: This is only to be used when the EBB7 is supported by IMB7 insulating mounting blocks, it should not be used with the smaller SMB7 mounting blocks.



HOW TO ORDER



MTL7700 barriers

Select by barrier number and polarity, e.g. MTL7728+

Mounting accessories

THR2 Standard DIN-rail, 35 x 7.5mm
THR7000 T-section DIN-rail, specially-plated,

35 x 7.5mm, 1m length

ISP7000 Insulating spacer

ADB700 Adaptor bracket to convert MTL700

Standard earthing/earth-rail accessories

ETL7000 Earth terminal, DIN-rail mounted IMB57 Insulating mounting block ERB57S Earth-rail bracket, straight ERB57O Earth-rail bracket, offset ERL7 Earth rail, 1m length ETM7 Earth terminal, pack of 50

Standard tagging accessories

TAG57 Tagging strip, 1m length

TGL7700 Tagging strip labels, set of 10 x 0.5m

Bussed power links

BPL7700 Pack of 100



Enclosures

DX070 Enclosure, for MTL7700 x 5
DX170 Enclosure, for MTL7700 x 13
DX430 Enclosure, for MTL7700 x 33

Spares (all in packs of 10)

SAF7712 Safe-area terminals 1 & 2
HAZ7734 Hazardous area terminals 3 & 4
SAF7756 Safe-area terminals 5 & 6
HAZ7778 Hazardous area terminals 7 & 8

TH7700 Tag holder



INM7700 INA7700 INM57ENC

Instruction manual, MTL7700 range ATEX information, MTL7700 range Instruction manual, MTL5000/7000

range Enclosures
CD7700... Customer drawings



Great Marlings, Butterfield, Luton Beds, LU2 8DL, UK. Tel: + 44 (0)1582 723633 Fax: + 44 (0)1582 422283 E-mail: mtlenquiry@eaton.com www.mtl-inst.com © 2017 Eaton All Rights Reserved Publication No. EPS7700 Rev 12 200917 EUROPE (EMEA):

+44 (0)1582 723633 mtlenquiry@eaton.com

THE AMERICAS:

+1 800 835 7075 mtl-us-info@eaton.com

ASIA-PACIFIC:

+65 6 645 9888 sales.mtlsing@eaton.com

APPROVALS

(for the latest certificate information and cable parameters, see www.mtl-inst.com/certificates)

	Region	UK	UK	USA	Canada/USA	Japan	
EN 60079-11:2012	(Authority)	(BASEEFA)	(BASEEFA) Systems	(FM)	(CSA)	(TIIS)	
Model No. Certificate No. September 1			EN 50039		UL698, UL913, UL1604 IEC60079, C22.2	See Certificates	
MTL770F+ BAS01ATEX7217 EX01E2219 3010737 1345550	Approved for	[Ex ia Ga] IIB ‡	1	ABCDEFG- SCI-942; NI/I/2/ABCD/T4 [I/0] AEx[ia]IIC – SCI-942 Entity; NI/1/2/IIC/T4 Ta=60°C except †	C,D; Ex nA [ia] IICT4 Class 1, Zone 2, AEx nA		
MTL7707+ BAS01ATEX7217 Ex01E2219 3010737 1345550 MTL7707P+ BAS01ATEX72181 Ex01E2204 3010737+ 1345550 MTL7716+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16434 MTL7715+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16434 MTL7722+/- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16435 MTL7722+/- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16436 MTL7728+- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16436 MTL7728P+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16436 MTL7741 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16612 MTL7742 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16613 MTL7743 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16616 MTL7755ac BAS01ATEX7217 Ex01E2219 3010737 1345550	Model No.	Certificate No.					
MTL7707P+ BAS01ATEX7218‡ Ex01E2220‡ 3010737‡ 1345550 C16433 MTL7715+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16434 MTL7715+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16434 MTL7722+/- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16436 MTL7728+/-/ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16436 MTL7728+-/ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16436 MTL7728+-/ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16436 MTL774B+- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16612‡ MTL7741 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16612‡ MTL7743 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16616 MTL7744 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16616 MTL7756ac BAS01ATEX7217 <t< th=""><th>MTL7706+</th><th>BAS01ATEX7217</th><th>Ex01E2219</th><th>3010737</th><th>1345550</th><th></th></t<>	MTL7706+	BAS01ATEX7217	Ex01E2219	3010737	1345550		
MTL7710+/- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16433 MTL7715+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16434 MTL7715P+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16435 MTL7728+/-Jac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16397 MTL7728+/-Jac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16397 MTL7728+/-Jac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16436 MTL7741 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16613 MTL7741 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16613 MTL7743 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16616 MTL7744 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16616 MTL7755ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16616 MTL776ac BAS01ATEX7217 Ex0	MTL7707+	BAS01ATEX7217	Ex01E2219	3010737	1345550		
MTL7715+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16434 MTL7715P+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16611 MTL7728+/- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16337 MTL7728P+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16436 MTL772P+ BAS01ATEX7218 Ex01E2219 3010737 1345550 C16436 MTL7741 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16612‡ MTL7741 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16613 MTL7742 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16614 MTL7743 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16614 MTL7744 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16616 MTL77545 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16617 MTL7756ac BAS01ATEX7217 Ex01E2219	MTL7707P+	BAS01ATEX7218‡	Ex01E2220‡	3010737‡	1345550		
MTL7715P+ BASOIATEX7217 Ex01E2219 3010737 1345550 C16611 MTL7728+/-ac BASOIATEX7217 Ex01E2219 3010737 1345550 C16435 MTL7728+/-ac BASOIATEX7217 Ex01E2219 3010737 1345550 C16397 MTL7728P+ BASOIATEX7217 Ex01E2219 3010737 1345550 C16436 MTL774P+ BASOIATEX7217 Ex01E2219 3010737 1345550 C16612‡ MTL7741 BASOIATEX7217 Ex01E2219 3010737 1345550 C16613 MTL7742 BASOIATEX7217 Ex01E2219 3010737 1345550 C16614 MTL7743 BASOIATEX7217 Ex01E2219 3010737 1345550 C16616 MTL7744 BASOIATEX7217 Ex01E2219 3010737 1345550 C16616 MTL7755ac BASOIATEX7217 Ex01E2219 3010737 1345550 C16616 MTL7756ac BASOIATEX7217 Ex01E2219 3010737 134550 C16437 MTL7761ac BASOIATEX7217 Ex01E2219	MTL7710+/-	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16433	
MTL7722+/- BAS01ATEX7217 EX01E2219 3010737 1345550 C16435 MTL7728+/-/ac BAS01ATEX7217 EX01E2219 3010737 1345550 C16397 MTL7728P+ BAS01ATEX7217 EX01E2219 3010737 1345550 C16436 MTL774P+ BAS01ATEX7217 EX01E2219 3010737 1345550 C16612‡ MTL7741 BAS01ATEX7217 EX01E2219 3010737 1345550 C16613 MTL7743 BAS01ATEX7217 EX01E2219 3010737 1345550 C16615 MTL7744 BAS01ATEX7217 EX01E2219 3010737 1345550 C16616 MTL7745 BAS01ATEX7217 EX01E2219 3010737 1345550 C16616 MTL7755ac BAS01ATEX7217 EX01E2219 3010737 1345550 C16616 MTL7756ac BAS01ATEX7217 EX01E2219 3010737 1345550 C16430 MTL7760ac BAS01ATEX7217 EX01E2219 3010737 1345550 C16618 MTL7761ac BAS01ATEX7217 EX01E2219	MTL7715+	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16434	
MTL7728+/−/ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16397 MTL7729P+ BAS01ATEX7218 Ex01E2219 3010737 1345550 C16436 MTL7729P+ BAS01ATEX7218 Ex01E2219 3010737 1345550 C166124 MTL7741 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16613 MTL7742 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16614 MTL7743 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16616 MTL7745 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16616 MTL7755ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16616 MTL7756ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16450 MTL776bac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16430 MTL776bac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16618 MTL776bac BAS01ATEX7217 Ex01E2219	MTL7715P+	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16611	
MTL7728P+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16436 MTL772P+ BAS01ATEX7218‡ Ex01E220± 3010737‡ 1345550 C16612‡ MTL7741 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16614 MTL7742 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16614 MTL7744 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16616 MTL7745 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16616 MTL7755ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16616 MTL7756ac BAS01ATEX7217 Ex01E2219 3010737† 1345550 C16450 MTL7756ac BAS01ATEX7217 Ex01E2219 3010737† 1345550 C16437 MTL7761ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16618 MTL7761ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16438 MTL7764ac BAS01ATEX7217 Ex01E2219<	MTL7722+/-	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16435	
MTL7729P+ BAS01ATEX7218‡ Ex01E2220‡ 3010737‡ 1345550 C16612‡ MTL7741 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16613 MTL7742 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16614 MTL7743 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16615 MTL7744 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16616 MTL7755ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16450 MTL7756ac BAS01ATEX7217 Ex01E2219 3010737† 1345550 C16617 MTL7756ac BAS01ATEX7217 Ex01E2219 3010737† 1345550 C16437 MTL7760ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16618 MTL7761ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16619 MTL77644 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16438 MTL77644 BAS01ATEX7217 Ex01E22	MTL7728+/-/ac	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16397	
MTL7741 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16613 MTL7742 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16614 MTL7743 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16616 MTL7744 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16616 MTL7745 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16617 MTL7755ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16450 MTL7756ac BAS01ATEX7217 Ex01E2219 3010737† 1345550 C16437 MTL7760ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16618 MTL7761ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16619 MTL7761ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16438 MTL7761ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16438 MTL7761ac BAS01ATEX7217 Ex01E2219	MTL7728P+	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16436	
MTL7742 BASO1ATEX7217 Ex01E2219 3010737 1345550 C16614 MTL7743 BASO1ATEX7217 Ex01E2219 3010737 1345550 C16615 MTL7744 BASO1ATEX7217 Ex01E2219 3010737 1345550 C16616 MTL7755ac BASO1ATEX7217 Ex01E2219 3010737 1345550 C16450 MTL7756ac BASO1ATEX7217 Ex01E2219 3010737 1345550 C16437 MTL7756ac BASO1ATEX7217 Ex01E2219 3010737 1345550 C16437 MTL776ac BASO1ATEX7217 Ex01E2219 3010737 1345550 C16618 MTL776ac BASO1ATEX7217 Ex01E2219 3010737 1345550 C16618 MTL7761ac BASO1ATEX7217 Ex01E2219 3010737 1345550 C16438 MTL7764ac BASO1ATEX7217 Ex01E2219 3010737 1345550 C16440 MTL7764ac BASO1ATEX7217 Ex01E2219 3010737 1345550 C16440 MTL7765ac BASO1ATEX7217 Ex01E2219	MTL7729P+	BAS01ATEX7218‡	Ex01E2220‡	3010737‡	1345550	C16612‡	
MTL7743 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16615 MTL7744 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16616 MTL7745 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16617 MTL7755ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16450 MTL7756ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16437 MTL7760ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16618 MTL7761ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16438 MTL7761ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16438 MTL7764+/- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16440 MTL7764ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16440 MTL7766ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16441 MTL7766ac BAS01ATEX7217 Ex01E2219 <th>MTL7741</th> <th>BAS01ATEX7217</th> <th>Ex01E2219</th> <th>3010737</th> <th>1345550</th> <th>C16613</th>	MTL7741	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16613	
MTL7744 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16616 MTL7745 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16617 MTL7755ac BAS01ATEX7217 Ex01E2219 3010737† 1345550 C16450 MTL7756ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16618 MTL7760ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16618 MTL7760ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16619 MTL7761ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16438 MTL7761ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16438 MTL7761ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16438 MTL7761ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16443 MTL7761ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16440 MTL7764ac BAS01ATEX7217 Ex01E2219<	MTL7742	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16614	
MTL7745 BAS01ATEX7217 Ex01E2219 3010737 1345550 C16617 MTL7755ac BAS01ATEX7217 Ex01E2219 3010737† 1345550 C16450 MTL7756ac BAS01ATEX7217 Ex01E2219 3010737† 1345550 C16437 MTL776ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16619 MTL7760ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16619 MTL7761ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16438 MTL7761ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16440 MTL7764ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16620 MTL7766ac BAS01ATEX7217 Ex01E221	MTL7743	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16615	
MTL7755ac BAS01ATEX7217 Ex01E2219 3010737† 1345550 C16450 MTL7756ac BAS01ATEX7217 Ex01E2219 3010737† 1345550 C16437 MTL7758+/- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16618 MTL7760ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16619 MTL7761ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16438 MTL7761pac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16438 MTL7764+/- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16440 MTL7765ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16441 MTL7766ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16442 MTL7766ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16442 MTL7766ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16443 MTL7778ac BAS01ATEX7217 Ex	MTL7744	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16616	
MTL7756ac BAS01ATEX7217 Ex01E2219 3010737† 1345550 C16437 MTL7758+/- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16618 MTL7760ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16619 MTL7761ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16438 MTL7761ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16440 MTL7764+/- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16440 MTL7766ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16441 MTL7766ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16620 MTL7766ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16442 MTL7766ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16442 MTL7767+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16444 MTL7778ac BAS01ATEX7217 Ex01E	MTL7745	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16617	
MTL7758+/- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16618 MTL7760ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16619 MTL7761ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16438 MTL7761pac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16440 MTL7764+/- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16440 MTL7764ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16441 MTL7765ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16620 MTL7766ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16442 MTL776Pac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16443 MTL7778ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16621 MTL7787+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16445 MTL7788+ BAS01ATEX7217 Ex01E2	MTL7755ac	BAS01ATEX7217	Ex01E2219	3010737†	1345550	C16450	
MTL7760ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16619 MTL7761ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16438 MTL7761Pac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16440 MTL7764+/- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16440 MTL7764ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16441 MTL7765ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16620 MTL7766ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16442 MTL7766pac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16442 MTL7767+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16444 MTL7778ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16621 MTL7787+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16445 MTL7788+ BAS01ATEX7217 Ex01E22	MTL7756ac	BAS01ATEX7217	Ex01E2219	3010737†	1345550	C16437	
MTL7761ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16438 MTL7761Pac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16440 MTL7764+/- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16440 MTL7764ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16441 MTL7765ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16620 MTL7766ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16442 MTL7766+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16443 MTL7778ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16621 MTL7779+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16445 MTL7787+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16445 MTL7788+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16448 MTL7788+ BAS01ATEX7217 Ex01E2219<	MTL7758+/-	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16618	
MTL7761Pac BAS01ATEX7217 Ex01E2219 3010737 1345550 MTL7764+/- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16440 MTL7764ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16620 MTL7765ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16620 MTL7766ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16442 MTL7766Pac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16443 MTL7767+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16444 MTL7778ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16621 MTL7779+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16445 MTL7787+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16447 MTL7788+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16449 MTL7788+ BAS01ATEX7217 Ex01E2219 301073	MTL7760ac	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16619	
MTL7764+/- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16440 MTL7764ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16441 MTL7765ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16620 MTL7766ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16442 MTL7766Pac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16443 MTL7767+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16444 MTL7778ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16444 MTL7779+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16445 MTL7787+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16447 MTL7788+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16449 MTL7789+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16449 MTL7789+ BAS01ATEX7217 Ex01E2219 </th <th>MTL7761ac</th> <td>BAS01ATEX7217</td> <td>Ex01E2219</td> <td>3010737</td> <td>1345550</td> <td>C16438</td>	MTL7761ac	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16438	
MTL7764ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16441 MTL7765ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16620 MTL7766ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16442 MTL7766Pac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16443 MTL7767+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16444 MTL7778ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16445 MTL7787+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16447 MTL7787P+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16448 MTL7788+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16449 MTL7789+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16449 MTL7789+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16449 MTL7789+ BAS01ATEX7217 Ex01E2219 <th>MTL7761Pac</th> <td>BAS01ATEX7217</td> <td>Ex01E2219</td> <td>3010737</td> <td>1345550</td> <td></td>	MTL7761Pac	BAS01ATEX7217	Ex01E2219	3010737	1345550		
MTL7765ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16620 MTL7766ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16442 MTL7766Pac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16443 MTL7767+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16444 MTL7778ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16445 MTL7787+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16447 MTL7787P+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16448 MTL7788+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16449 MTL7789+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16449 MTL7789+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16449 MTL7796+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446 MTL7796- BAS01ATEX7217 Ex01E2219 <th>MTL7764+/-</th> <td>BAS01ATEX7217</td> <td>Ex01E2219</td> <td>3010737</td> <td>1345550</td> <td>C16440</td>	MTL7764+/-	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16440	
MTL7766ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16442 MTL7766Pac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16443 MTL7767+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16444 MTL7778ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16421 MTL7779+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16445 MTL7787+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16447 MTL7788+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16449 MTL7788+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16449 MTL7789+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16429 MTL7796+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446 MTL7796- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446	MTL7764ac	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16441	
MTL7766Pac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16443 MTL7767+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16444 MTL7778ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16621 MTL7779+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16445 MTL7787+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16447 MTL7787P+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16448 MTL7788+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16449 MTL7789+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16429 MTL7796+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446 MTL7796- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446	MTL7765ac	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16620	
MTL7767+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16444 MTL7778ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16621 MTL7779+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16445 MTL7787+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16447 MTL7787P+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16448 MTL7788+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16449 MTL7789+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16622 MTL7796+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446 MTL7796- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446	MTL7766ac	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16442	
MTL7778ac BAS01ATEX7217 Ex01E2219 3010737 1345550 C16621 MTL7779+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16445 MTL7787+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16447 MTL7787P+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16448 MTL7788+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16449 MTL7789+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16622 MTL7796+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446 MTL7796- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446	MTL7766Pac	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16443	
MTL7779+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16445 MTL7787+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16447 MTL7787P+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16448 MTL7788+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16449 MTL7788R+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16449 MTL7789+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16622 MTL7796+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446 MTL7796- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446	MTL7767+	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16444	
MTL7787+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16447 MTL7787P+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16448 MTL7788+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16449 MTL7788R+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16449 MTL7789+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16622 MTL7796+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446 MTL7796- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446	MTL7778ac	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16621	
MTL7787P+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16448 MTL7788+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16449 MTL7788R+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16449 MTL7789+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16622 MTL7796+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446 MTL7796- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446	MTL7779+	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16445	
MTL7788+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16449 MTL7788R+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16449 MTL7789+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16622 MTL7796+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446 MTL7796- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446	MTL7787+	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16447	
MTL7788R+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16449 MTL7789+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16622 MTL7796+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446 MTL7796- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446	MTL7787P+	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16448	
MTL7789+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16622 MTL7796+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446 MTL7796- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446	MTL7788+	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16449	
MTL7796+ BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446 MTL7796- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446	MTL7788R+	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16449	
MTL7796- BAS01ATEX7217 Ex01E2219 3010737 1345550 C16446	MTL7789+	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16622	
	MTL7796+	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16446	
MTL7798 NI only	MTL7796-	BAS01ATEX7217	Ex01E2219	3010737	1345550	C16446	
, , , , , , , , , , , , , , , , , , , ,	MTL7798			NI only			

Note: For FM compliance, the MTL7700 range of barriers shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.

- ‡ Certified to CENELEC IIB/FM Grps C-G only.
- † USA (FM) $T_a = 65$ °C See "**Approved** for" above



© 2017 Eaton All Rights Reserved Publication No. EUROPE (EMEA): +44 (0)1582 723633 mtlenquiry@eaton.com THE AMERICAS: +1 800 835 7075 mtl-us-info@eaton.com ASIA-PACIFIC: +65 6 645 9888 sales.mtlsing@eaton.com

CORRELATION BETWEEN MTL7700 - MTL7000 - MTL700 BARRIERS (IIC)

Module No.	Bussed Power	MTL7000 Equivalent	MTL7000 Original Certificate Number(s)	MTL7000 ATEX Certificate Number(s)	MTL700 equivalent	MTL700 Original Certificate Number(s)	MTL700 ATEX Certificate Number(s)	Typical Application	
MTL7710+/-	No	Half of MTL7162+	Ex95C2261	BAS99ATEX7285	MTL710+/-	Ex832452	BAS01ATEX7202	4/6V Systems	
MTL7715+	No	N/A	N/A	N/A	MTL715+	Ex832452	BAS01ATEX7202	12V Systems	
MTL7715P+	No	N/A	N/A	N/A	MTL715P+	Ex92C2373	BAS01ATEX7202	12V Systems	
MTL7722+/-	No	MTL7122+/-	Ex95C2261	BAS99ATEX7285	MTL722+/-	Ex832452	BAS01ATEX7202	General Purpose	
MTL7728+/-	No	MTL7028+/- MTL7128+/-	Ex95C2261	BAS99ATEX7285	MTL728+/-	Ex832452	BAS01ATEX7202	Analogue / Digital	
MTL7728ac	No	N/A	N/A	N/A	MTL728ac	Ex832452	BAS01ATEX7202	General Purpose	
MTL7728P+	No	MTL7128P+	Ex95C2261	BAS99ATEX7285	MTL728P+	Ex92C2373	BAS01ATEX7202	Analogue / Digital	
MTL7755ac	No	MTL7055ac	Ex95C2261	BAS99ATEX7285	MTL755ac	Ex832452	BAS01ATEX7202	RTD, Grounded	
MTL7756ac	No	MTL7056ac	Ex95C2261	BAS99ATEX7285	N/A	N/A	N/A	RTD, Grounded	
MTL7758+/-	No	N/A	N/A	N/A	MTL758	Ex83453	BAS01ATEX7217	Active sensors,	
MTL7760ac	No	N/A	N/A	N/A	MTL760ac	Ex832452	BAS01ATEX7202	Active sensors, Thermocouples	
MTL7761ac	No	MTL7261ac	Ex95C2261	BAS99ATEX7285	MTL761ac	Ex832452	BAS01ATEX7202	Strain Gauges	
MTL7761Pac	No	MTL7061Pac MTL7161Pac	Ex95C2261	BAS99ATEX7285	MTL761Pac	Ex92C2373	BAS01ATEX7202	Load cell	
MTL7764+/-	No	MTL7164+/-	Ex95C2261	BAS99ATEX7285	MTL764+/-	Ex832452	BAS01ATEX7202	High resistance	
MTL7764ac	No	MTL7264ac	Ex95C2261	BAS99ATEX7285	MTL764ac	Ex832452	BAS01ATEX7202	Strain / Level Gauges	
MTL7765ac	No	N/A	N/A	N/A	MTL765ac	Ex832452	BAS01ATEX7202	General Purpose	
MTL7766ac	No	N/A	N/A	N/A	MTL766ac	Ex832452	BAS01ATEX7202	Strain Gauges	
MTL7766Pac	No	MTL7066Pac MTL7166Pac	Ex95C2261	BAS99ATEX7285	MTL766Pac	Ex92C2373	BAS01ATEX7202	Strain Gauges	
MTL7767+	No	MTL7167+	Ex95C2261	BAS99ATEX7285	MTL767+	Ex832452	BAS01ATEX7202	Dual MTL715	
MTL7779+	No	N/A	N/A	N/A	MTL779+	Ex832452	BAS01ATEX7202	Dual MTL728	
MTL7787+/-	Yes	MTL7087+ MTL7187+	Ex95C2261	BAS99ATEX7285	MTL787S+	Ex832452	BAS01ATEX7202	Analogue / Digital	
MTL7787P+	Yes	MTL7087P+ MTL7187P+	Ex95C2261	BAS99ATEX7285	MTL787SP+	Ex92C2373	BAS01ATEX7202	Analogue / Digital	
MTL7788+	Yes	N/A	N/A	N/A	MTL788+	Ex832452	BAS01ATEX7202	Transmitters	
MTL7788R+	Yes	N/A	N/A	N/A	MTL788R+	Ex832452	BAS01ATEX7202	1—5V systems	
MTL7796+/-	No	MTL7096- MTL7196-	Ex95C2261	BAS99ATEX7285	MTL796+/-	Ex832452	BAS01ATEX7202	Vibration sensors	

